

**MODEL AIO 2
ALL IN ONE WEATHER SENSOR**

**OPERATION MANUAL
Document No. AIO 2-9800 Rev. E**



**Met One
Instruments**

1600 Washington Blvd.
Grants Pass, Oregon 97526
Telephone 541-471-7111
Facsimile 541-471-7116

Regional Sales & Service
3206 Main St. Suite 106
Rowlett, Texas 75088
Telephone 972-412-4715
Facsimile 972-412-4716

Copyright Notice

AIO 2 Weather Sensor Manual

© Copyright 2018 Met One Instruments, Inc. All Rights Reserved Worldwide. No part of this publication may be reproduced, transmitted, transcribed, stored in a retrieval system, or translated into any other language in any form by any means without the express written permission of Met One Instruments, Inc.

Technical Support

This manual is structured by customer feedback to provide the required information for setup, operation, testing, maintaining, and troubleshooting your AIO 2 Weather Sensor. Should you still require support after consulting your printed documentation, we encourage you to contact one of our expert Technical Service representatives during normal business hours of 7:00 a.m. to 4:00 p.m. Pacific Standard Time, Monday through Friday. In addition, technical information and service bulletins are often posted on our website. Please contact us and obtain a Return Authorization (RA) number before sending any equipment back to the factory. This allows us to track and schedule service work and to expedite customer service. Please have your instrument serial number available when contacting the manufacturer.

Contact	Tel: + 541 471 7111	Address:	Met One Instruments, Inc.
Information:	Fax: + 541 471 7116		1600 Washington Blvd
	Web: http://www.metone.com		Grants Pass, Oregon 97526
	Email: service@metone.com		U.S.A.

Safety Notice

The contents of this manual have been checked against the hardware and software described herein. Since deviations cannot be prevented entirely, we cannot guarantee full agreement. However, the information in this manual is reviewed regularly and any necessary corrections are included in subsequent editions. Faultless and safe operation of the product presupposes proper transportation, storage, and installation as well as careful operation and maintenance. The seller of this equipment cannot foresee all possible modes of operation in which the user may attempt to utilize this instrumentation. The user assumes all liability associated with the use of this instrumentation. The seller further disclaims any responsibility for consequential damages.

Electrical & Safety Conformity

The manufacturer certifies that this product operates in compliance with the following standards and regulations:

FDA/CDRH This product is tested and complies with 21 CFR, Subchapter J, of the Health and Safety Act of 1968 US 21 CFR 1040.10

Table of Contents

1. Introduction & Overview – AIO 2 All In One Weather Sensor	6
1.1. Overview	6
2. Specifications	7
3. Unpacking & Installation	8
3.1. Unpacking	8
3.2. Deployment	9
3.2.1. Tripod / Pipe top Installation:.....	9
3.2.2. Universal Mounting Arm Installation:	12
3.3. Input / Output Connections	13
3.4. Operational Checkout	14
3.5. Maintenance	14
3.6. Setting Magnetic Declination	14
4. User Selectable Options	15
5. User Interface	16
6. Standard Configuration.....	18
7. Appendix A.....	19
7.1. Terminal Mode and SDI Commands	19
7.1.1. H,h,? – Display Help Menu	19
7.1.2. BV – Battery Voltage Printout Toggle On/Off.....	19
7.1.3. CV – Compass Measurement Printout Toggle On/Off.....	20
7.1.4. ID – View / Set Instrument ID.....	20
7.1.5. MA – View / Set Modbus Address.....	20
7.1.6. ME – Metric or English Units.....	20
7.1.7. SU –Wind Speed Units.....	21
7.1.8. TU –Temperature Units.....	21
7.1.9. PU –Barometric Pressure Units.....	21
7.1.10. RU –Rain Units	21

7.1.11.	MD –Magnetic Declination	22
7.1.12.	OI –Output Interval	22
7.1.13.	ST – Serial Trigger	23
7.1.14.	SA – SDI-12 Address	23
7.1.15.	SC – Solar Calibration	23
7.1.16.	RT – Output Record Type	23
7.1.17.	RV – Software Version Number	23
7.2.	SDI-12 Commands	24
8.	Modbus	26
8.1.	Modbus operation:	26
	3X Registers	26
	4X Registers	26
9.	Appendix B	27
9.1.	Theory of Operation	27

1. Introduction & Overview – AIO 2 All In One Weather Sensor

1.1. Overview

The AIO 2 Weather Sensor provides measurements of wind speed, wind direction, ambient air temperature, relative humidity, and barometric pressure in a single, compact, rugged unit. It integrates a folded-path, low-power sonic anemometer with a precision thermistor temperature sensor, fast-response capacitive relative humidity sensor, and a state-of-the-art barometric pressure sensor. It also includes an internal flux-gate compass that allows for automatic alignment of wind direction to magnetic north, regardless of the sensor's orientation.

The small footprint and power efficiency of the AIO 2 make it ideal for remote regions, urban environments, air quality networks, construction/remediation sites, and other network applications. The unit can be used in permanent (cooperative weather networks, schools, public information dissemination) or temporary (emergency response, audit, research program support) installations.

Designed for maximum portability and utility, the AIO 2 is well suited for rapid deployment and use by one person under all conditions. The unit may be mounted on a tower, tripod or vehicle mast. Data output is a serial, digital message that can be interfaced to most data logging systems.

The AIO 2 even has the capability to connect an external contact closure rain gauge (such as the Met One 360 or 370) and/or solar radiation sensor (such as the Met One 096A-2). If these inputs are present, their measurements are then integrated into the AIO 2 serial data output.

2. Specifications

PARAMETER	SPECIFICATION
Wind Speed Operating Range	0 to 75 m/s (0 to 168 mph)
Wind Speed Calibrated Range	0 to 60 m/s (0 to 134 mph)
Wind Speed Accuracy	±0.5 m/s or 5% of reading (whichever is greater)
Wind Speed Resolution	0.1 m/s
Wind Direction Range	0 to 360 degrees
Wind Direction Accuracy	±5° (including Compass)
Wind Direction Resolution	1.0°
Alignment Compass Accuracy	±2°
Alignment Compass Resolution	1°
Temperature Range	-40 to +60 °C (-40 to +140 °F)
Temperature Accuracy	±0.2 °C from 0 to 60 °C, ±0.5 °C from -40 to 0 °C
Temperature Resolution	0.1 °C
Relative Humidity Range	0 to 100%
Relative Humidity Accuracy	±3% 25 °C
Relative Humidity Resolution	1.0%
Barometric Pressure Range	600 to 1100 hPa
Barometric Pressure Accuracy	±0.5 hPa 25 °C
Barometric Pressure Resolution	0.1 hPa
External Rain Gauge Input	Resolution 0.25mm or 0.01", user selectable
External Solar Radiation Sensor Input	Measured in W/m ²
Measurement Rate Output	1 Hz
Signal Output Type	RS-232, RS-485, and SDI-12
Operating Temperature	-40 to +60 °C (-40 to +140 °F)
Operating Relative Humidity	0 to 100%
Dimensions	4.5 inches diameter, 11 inches height
Shipping Weight	6 pounds (including packaging)

3. Unpacking & Installation

3.1. Unpacking

Any damages incurred to the equipment during shipping are the responsibility of the carrier. If any damage to the shipment is noticed before unpacking, a claim must be filed with the commercial carrier immediately. You should follow any special unpacking instructions provided by the carrier as you then carefully remove all items from the containers and inspect each component. It is recommended to document and photograph all damaged packages and items before, during, and after unpacking them.

Unpack the AIO 2 and accessories and make a visual inspection of the contents; contact your supplier if anything is missing. The AIO 2 Weather Sensor ships with the following items:

- AIO 2 All In One Weather Sensor.
- Calibration certificate.
- Operation manual (this document).

Optional Accessories that may be purchased include:

- 10523 ¾" IPS pipe vertical mounting adaptor
- 10106 Universal mounting arm
- 10600 Interface station – provides wiring terminals, 12VDC power, USB and DB9 serial connections.
- WeatherView Software
- USB Driver CD
- Comet Terminal Software CD

The required 10624 signal cable is sold separately. It is custom built to the desired length.

Contact Met One Instruments (see the Technical Support section at the beginning of this manual) to arrange for any replacement items needed.

Please keep the carton(s) and associated packing materials for reuse.

3.2. Deployment

3.2.1. Tripod / Pipe top Installation:

The AIO 2 can be quickly and easily deployed on top of a Met One 905 tripod or any other vertical $\frac{3}{4}$ " IPS pipe using the optional 10523 vertical mount.



Route the 10624 signal cable connector end through the 10523 mount adaptor as shown below.



Plug the cable connector into the base of the AIO 2 and turn the connector sleeve clockwise (as seen from below the sensor) until tight. Then slide the AIO 2 onto the top of the 10523 mount adaptor and tighten the two slotted base set screws as shown below.



Position the cable in the slot on the side of the mount and then slide the assembly onto the tripod mast or pipe. Tighten the 2 set screws on the 10523 mount to affix it to the tripod/pipe.



The AIO 2 includes an internal alignment compass so the adaptor and AIO 2 sensor can face any direction and still correctly read wind direction (as referenced to Magnetic North). The MD command can be used to set a magnetic declination to reference the wind direction reading to True North. See section 3.6 for more details about setting the magnetic declination.

Run the signal cable from the mount to the data collection device being used (such as a data logger or computer) following the wiring connections listed in section 3.3.

3.2.2. Universal Mounting Arm Installation:

If a tripod or $\frac{3}{4}$ " pipe is not available, the optional 10106 Universal Mounting Arm can be used to mount the AIO 2 horizontally or vertically to a variety of vertical posts or pipes. The included hose clamps will fit up to 3" diameter posts, but larger user supplied hose clamps can be substituted to mount the arm to larger diameter structures.

10106 Universal Mounting Arm Orientation Options



Horizontal



Vertical

3.3. Input / Output Connections

10624 Cable Wire Color Designations:

<u>RED</u>	<u>POWER POSITIVE (8-36VDC, 30mA nominal @ 12VDC)</u>
<u>BLK</u>	<u>POWER COMMON</u>
<u>BLU</u>	<u>SDI-12</u>
<u>GRN</u>	<u>SIGNAL COMMON</u>
<u>WHT</u>	<u>RS-232 TX</u>
<u>BRN</u>	<u>RS-232 RX</u>
<u>YLW</u>	<u>RS-485 +A</u>
<u>GRY</u>	<u>RS-485 -B</u>
<u>ORN</u>	<u>EXTERNAL RAIN GAUGE OPTION INPUT</u>
<u>VIO</u>	<u>EXTERNAL SOLAR RADIATION SENSOR OPTION INPUT</u>
<u>WHT/BRN</u>	<u>SHIELD (must be grounded for transient protection to function)</u>

Warning: Do not short any of the signal or power wires to ground or to each other.

Maximum Cable Length Considerations:

The maximum recommended cable length depends on the communication protocol to be used:

RS-232C	50FT maximum
RS-485	4000FT maximum
SDI-12	200FT maximum

Connecting to the optional 10600 Interface Base Station

- The optional 10600 Interface Base Station provides:
 - 12VDC power to the sensor
 - Convenient wiring terminal blocks for the AIO 2 sensor
 - Connection points for optional external Rain gauge and Solar radiation sensors.
 - USB and DB9 serial port outputs for easy Computer connectivity.
- See the included 10600 manual for use and connection details.

3.4. Operational Checkout

Connect the AIO 2 to your data logger or recording electronics. Connect power to the sensor cable per wiring diagram in section 3.3. The AIO 2 will automatically start streaming its serial output and your recording electronics should start displaying or recording measurements from the AIO 2. Verify the data seems reasonable by comparing it to data from a local weather source. If the data looks OK, the unit is in operation. If data is questionable, contact Met One Instruments, Inc. Service Department for further guidance (see the Technical Support section at the beginning of this manual).

3.5. Maintenance

The unit has no moving parts and therefore requires no periodic maintenance for wear items. It is recommended that the data be checked every 6 -12 months to be sure there has been no failure of any of the electrical components. This can be done by placing a small container (at least 12inch diameter) over the sensor to zero check the wind measurement. The ambient temperature, relative humidity, and pressure readings can be verified against collocated devices such as the Met One 083E-1-35 T/RH sensor and Met One 092 BP sensor.

3.6. Setting Magnetic Declination

The internal flux gate compass automatically corrects the wind direction in the AIO 2 to magnetic North. This means that the unit will *not* require directional alignment or orientation upon deployment.

If it is necessary to measure wind direction referenced to True North it is important to understand and know the magnetic declination of the area in which the sensor is being operated. The declination in the AIO 2 is factory set at zero degrees. To change this, refer to the MD command instruction in section 7.1.11 for setting the Magnetic Declination.

4. User Selectable Options

The following User Defined Options can be set following the instructions detailed in Appendix A.

BV	Battery Voltage Printout Toggle On/Off
CV	Compass Reading Printout Toggle On/Off
ID	View / Set Instrument ID
MA	Set MODBUS Address
MD	Set Magnetic Declination
ME	Metric or English Units
OI	Set Output Interval
PU	Set Pressure Units
RT	Output Record Type
RU	Set Rain Units
RV	Display Firmware Version Number
SA	SDI Address
SC	Solar Option Calibration Constant
ST	Set Serial Trigger Address
SU	Set Wind Speed Units
TU	Set Temperature Units
Q	Quit Terminal Mode and Save changes

5. User Interface

The output of the AIO 2 is a fixed length, comma delimited, serial data stream. The serial output is factory set for 9600 baud, no parity, 8 data bits, 1 stop bit, and no flow control. The output interval default is once per second. This may be changed using the *OI* command (see Appendix A). The data is easily viewed and can be displayed and captured using Met One Instruments' Comet Software or other terminal communication program.

An **example** of the standard output format is shown below:

000.6,272,+023.6,022,0974.3,000.00,0000,12.7,U0,*02257 CR/LF

Each parameter is a fixed length with leading zeros separated by a comma. The string terminates with a Carriage Return and Line Feed. Field parameters are defined as:

000.6,272,+023.6,022,0974.3,000.00,0000,12.7,U0,*02257 CR/LF
WS,WD,AT,RH,BP,RN,SR,BV,CONFIG,Checksum

The wind speed, temperature, pressure and rainfall units can be changed with the *SU*, *TU*, *PU*, and *RU* terminal commands respectively. Please refer to Appendix A for more information.

NOTE: the internal alignment compass reading can be added to the output string using the CV command; see Section 7.1.3 for details and an output string example.

The AIO 2 output can also be configured to emulate the Legacy AIO 102780 output data format. An **example** of the Legacy AIO output format is shown below:

002.6, 219, +020.8, 042, 1013.2, *1787CR/LF

Each parameter is a fixed length with leading zeros separated by a comma and one space. The string terminates with a Carriage Return and Line Feed. Field parameters are defined as:

002.6,	219,	+020.8,	042,	1013.2,	*1787
WS	WD	Temp	RH	BP	Check Sum

Note: when displaying the pressure in In/Hg, there will be an extra leading zero character but the fixed length of the field will not change.

A check sum parameter will be added to the end of the message (*9999).

The check sum is the addition of all the characters from the start of the message through the first character preceding the asterisk (*). The check sum is expressed as a decimal number. This is a 16 bit sum and should not overflow past 4 digits given the number of characters in the output string.

Polled data mode (RS232 or RS485)

The sensor can be set for polled data mode instead of continuous serial output by setting the OI command to Zero, and using the serial trigger string to request a data string. Refer to the *ST* terminal command in Appendix A for instructions on setting the Serial Trigger.

SDI-12 Interface

In addition to the above communications methods, the sensor can be polled by an SDI-12 Master Station for data. This operates completely independent of the RS232 or RS485 communications and can be used in conjunction with those methods. Data are polled using a series of SDI-12 commands. Please see appendix A for a list of supported SDI commands. The default SDI Address for the AIO 2 is zero.

Please consult your data-logger manual for more information on SDI interfaces or call Met One for additional help.

6. Standard Configuration

Serial Interface

The serial interface is fixed at 9600 Baud and configured for No Parity, 8 Data Bits and 1 Stop Bit, with no flow control.

Wind Speed

The Wind Speed unit choices are MPH or M/S. The default is M/S. The Speed range for M/S is 0-60. The Speed range for MPH is 0-134.

Temperature

The Temperature unit choices are Degrees C or Degrees F. The default is Degrees C. The range for Degrees C is -40 to +60, the range for Degrees F is -40 to +140.

Pressure

Pressure Range choices are In/Hg, Millibars, or mm/Hg, and the default is Millibars. The Pressure range for Millibars is 600-1100, for In/Hg is 17.72 to 32.48, and for mm/hG is 450 to 825.

Precipitation Input

The Precipitation resolution can be 0.25mm/tip or 0.01"/tip. 0.25mm/tip is the default.

Solar Radiation Input

The Solar Radiation input units are watts per square meter. The default calibration constant is 2 W/m² per mV (1.000VDC = 2000 W/m²).

7. Appendix A

7.1. Terminal Mode and SDI Commands

RS232 / RS485 Terminal Mode Commands

Terminal mode is activated by entering three carriage return characters within a 2 second period. Terminal mode times-out after 2 minutes of inactivity.

Successful entry into Terminal Mode will return an asterisk prompt:

7.1.1. H,h,? – Display Help Menu

- BV - Battery Voltage Printout Toggle On/Off
- CV - Compass Heading Printout Toggle On/Off
- ID - View / Set Instrument ID
- MA - Set MODBUS Address
- MD - Set Magnetic Declination
- ME - Metric or English Units
- OI - Set Output Interval
- PU - Set Pressure Units
- SA - SDI Address
- SC - Solar Calibration
- RT - Output Record Type
- ST - Set Serial Trigger Address
- SU - Set Speed Units
- TU - Set Temperature Units
- RV - Display Firmware Version Number
- RU - Set Rain Units
- Q - Quit command mode and save any changes

NOTE: The commands noted in this appendix will change both the RS232 and RS485 outputs. The SDI-12 output can be configured independently. See pages below for SDI-12 commands.

7.1.2. BV – Battery Voltage Printout Toggle On/Off

This command enables or suppresses the Battery Voltage reading in the serial string output.

COMMAND	RESULT
BV<cr>	Report current setting
BV0<cr>	Battery Voltage Measurement removed from serial output 000.0,000,+024.5,045,0970.5,000.00,0000,M0,*02112
BV1<cr>	Battery Voltage Measurement enabled in serial output 000.0,000,+024.5,045,0970.5,000.00, 0000, 12.0 ,M0,*02344

7.1.3. CV – Compass Measurement Printout Toggle On/Off

This command enables or suppresses the Compass Reading in the serial string output.

COMMAND	RESULT
CV<cr>	Report current setting
CV0<cr>	Compass Measurement removed from serial output 000.0,000,+024.5,045,0970.5,000.00, 0000,12.0,M0,*02344
CV1<cr>	Compass Measurement enabled in serial output 000.0,000,+024.5,045,0970.5,000.00, 0000,12.0, 240 ,M0,*0254

7.1.4. ID – View / Set Instrument ID

Read or Set the Instrument ID

COMMAND	RESULT
ID<cr>	Report the Instrument ID setting (provides help)
ID XX<cr>	Set Instrument ID to number from 1 to 99

7.1.5. MA – View / Set Modbus Address

Read or Set the Modbus Address

COMMAND	RESULT
MA<cr>	Report the Modbus Address setting (provides help)
MA XX<cr>	Set Instrument ID to number from 1 to 247. Setting this value to 0 will disable Modbus.

7.1.6. ME – Metric or English Units

This command will set all units in the the serial port's output to Metric or English

COMMAND	RESULT
ME<cr>	Report Units setting
ME0<cr>	Set Units to Metric (Default): WS: m/s AT: Deg C BP: mbars RN: mm
ME1<cr>	Set Units to English: WS: MPH, AT: Deg F BP: inHg

	RN: inches
--	------------

7.1.7. SU –Wind Speed Units

Read or Set this serial port's output Units for Wind Speed

COMMAND	RESULT
SU<cr>	Report Units setting
SU0<cr>	M/S
SU1<cr>	MPH

7.1.8. TU –Temperature Units

Read or Set this serial port's output Units for Temperature

COMMAND	RESULT
TU<cr>	Report Units setting
TU0<cr>	Fahrenheit
TU1<cr>	Celsius

7.1.9. PU –Barometric Pressure Units

Read or Set this serial port's output Units for Pressure

COMMAND	RESULT
PU<cr>	Report Units setting
PU0<cr>	Millibars (Default)
PU1<cr>	Inches of Mercury
PU2<cr>	Millimeters of Mercury

7.1.10. RU –Rain Units

Read or Set this serial port's output Units for Pressure

COMMAND	RESULT
RU<cr>	Report Units setting
RU0<cr>	mm (Default)
RU1<cr>	Inches

7.1.11. MD –Magnetic Declination

The flux compass in the AIO 2 sensor provides Wind Direction to MAGNETIC north. Software in the Interface allows the setting of a declination angle to correct the Wind Direction output to TRUE north. It is recommended that this procedure be done in the lab, but can be done in the field as well. Once the declination angle is set in the sensor, it is stored in non-volatile memory, and does not have to be reset each time the sensor is fielded. The declination angle must be reset only if the system is used in a different geographical location separated by many miles from the location where the declination was originally set.

It is suggested that the magnetic declination be determined before performing this calibration. Visit the following web site for help in determining the correct declination for your site:

www.ngdc.noaa.gov/geomag/declination.shtml

Click “Compute your declination”. On the next page, enter either zip code, or select country and city, then click “Get Location” and then “Calculate”. Alternatively, you can enter longitude and latitude directly, and then click “Calculate”. Declination is reported in Degrees, Minutes and Seconds. Divide minute’s value by 60 to get decimal fraction of degrees (I.E. 50 minutes = 0.8 degrees). If the declination needs to be adjusted, please use the *MD* command as shown below.

Read or Set the Magnetic Declination

COMMAND	RESULT
MD<cr>	Report Magnetic Declination setting
MDXX.X<cr>	Set Declination to XX.X Degrees

Note: West declination values are entered and reported as negative values.

7.1.12. OI –Output Interval

Read or Set the Output Interval for this serial port

Note: This command is not supported by SDI-12.

COMMAND	RESULT
OI<cr>	Report Output Interval setting
OI0<cr>	For Serial Trigger (Address must be set with ST command).
OI1<cr>	Sensor Output every 1 second (Default)
OI2<cr>	Sensor Output every 2 seconds
OI3<cr>	Sensor Output every 5 seconds
OI4<cr>	Sensor Output every 15 seconds
OI5<cr>	Sensor Output every 30 seconds
OI6<cr>	Sensor Output every 60 seconds

7.1.13. ST – Serial Trigger

Read or Set the Serial Trigger character string (Poll command)

COMMAND	RESULT
ST<cr>	Report Serial Trigger string setting (provides help)
ST XXXXXX<cr>	Set Serial Trigger

7.1.14. SA – SDI-12 Address

Read or Set the SDI-12 Address, used to poll data in SDI-12 mode.

COMMAND	RESULT
SA<cr>	Report SDI-12 Address string setting (provides help)
SAX<cr>	Set SDI-12 Address, where 'x' is in the range [0-9], [A-Z] or [a-z] Case Sensitive.

7.1.15. SC – Solar Calibration

Read or Set the Solar Radiation Input Calibration Constant, units are in W/m² per mV.

COMMAND	RESULT
SC<cr>	Report Solar Radiation Input Calibration Constant Default is 2 W/m ² per mV (1.000V = 2000W/m ²)
SCX.XXX<cr>	Set Solar Calibration Constant to x.xxx in W/m ² per mV.

7.1.16. RT – Output Record Type

Read or Set the Output Record type.

COMMAND	RESULT
RT<cr>	Report Output Record Type
RT1<cr>	Set Output Record Type to Met Record format (default).
RT2<cr>	Set Output Record Type to AIO format for compatibility with legacy AIO 102780 systems.

7.1.17. RV – Software Version Number

Report the current Software Version Number

COMMAND	RESULT
RV<cr>	Report current Software Version

7.2. SDI-12 Commands

NAME	SDI-12 COMMAND	SENSOR RESPONSE
Address Query	?!	<i>a</i> <CR><LF> Where <i>a</i> = address
Acknowledge Active	<i>a</i> !	<i>a</i> <CR><LF> Where <i>a</i> = address
Send Identification	<i>a</i> !	<i>a</i> 13METONE AIO 2 2.0.0xxxxx<CR><LF> Where <i>a</i> =address and xxxxx = S/N
Change Address	<i>aAb</i> !	<i>b</i> <CR><LF> Where <i>b</i> = new address
Start Measurement	<i>aM</i> !	<i>a</i> 0009<CR><LF> Where <i>a</i> = address
Start Measurement with CRC	<i>aMC</i> !	<i>a</i> 0009{crc}<CR><LF> Where <i>a</i> = address and {crc} = CRC
Send Data	<i>aD0</i> !	<i>a+bbb.b+ccc.c+ddd.d+eee.e</i> <CR><LF> Where <i>a</i> = address, <i>bbb.b</i> = wind speed, <i>ccc.c</i> = wind direction, <i>ddd.d</i> = temperature, and Send Data <i>eee.e</i> = relative humidity
	<i>aD1</i> !	<i>a+ffff.f+gggg.g+hhhh+ii.ii</i> <CR><LF> Where <i>a</i> = address, <i>ffff.f</i> = barometric pressure, <i>gggg.g</i> = Rain Option, <i>hhhh</i> = Solar Option, and <i>ii.ii</i> = Power Supply Voltage
Start Concurrent Measurement	<i>aC</i> !	<i>a</i> 00009<CR><LF> Where <i>a</i> = address
Start Concurrent Measurement with CRC	<i>aCC</i> !	<i>a</i> 00009{crc}<CR><LF> Where <i>a</i> = address and {crc} = CRC
Continuous Measurements	<i>aR0</i> !	<i>a+bbb.b+ccc.c+ddd.d+eee.e</i> <CR><LF> Where <i>a</i> = address, <i>bbb.b</i> = wind speed, <i>ccc.c</i> = wind direction, <i>ddd.d</i> = temperature, and <i>eee.e</i> = relative humidity
	<i>aR1</i> !	<i>a+ffff.f+gggg.g+hhhh+ii.ii</i> <CR><LF> Where <i>a</i> = address, <i>ffff.f</i> = barometric pressure, <i>gggg.g</i> = Rain Option, <i>hhhh</i> = Solar Option, and <i>ii.ii</i> = Power Supply Voltage
Continuous Measurements with CRC	<i>aRC0</i> !	<i>a+bbb.b+ccc.c+ddd.d+eee.e</i> {crc}<CR><LF> Where <i>a</i> = address, <i>bbb.b</i> = wind speed, <i>ccc.c</i> = wind direction, <i>ddd.d</i> = temperature, <i>eee.e</i> = relative humidity, and {crc} = CRC
	<i>aRC1</i> !	<i>a+ffff.f+gggg.g+hhhh+ii.ii</i> {crc}<CR><LF> Where <i>a</i> = address, <i>ffff.f</i> = barometric pressure, <i>gggg.g</i> = Rain Option, <i>hhhh</i> = Solar Option, and <i>ii.ii</i> = Power Supply Voltage and {crc} = CRC

NAME	SDI-12 COMMAND	SENSOR RESPONSE
Report Wind Units	<i>aXSU!</i>	<i>aXSUb!</i> <CR><LF> Where <i>a</i> = address, and <i>b</i> = 0 for Meters per Second (default), or 1 for Miles per Hour
Set Wind Units <i>aXSUb</i>	<i>aXSUb!</i>	
Report Temperature Units	<i>aXTU!</i>	<i>aXTUd!</i> <CR><LF> Where <i>a</i> = address, and <i>d</i> = 0 for Celsius (default), or 1 for Fahrenheit
Set Temperature Units	<i>aXTUd!</i>	
Report Pressure Units	<i>aXPU!</i>	<i>aXPUf!</i> <CR><LF> Where <i>a</i> = address, and <i>f</i> = 0 for Millibars (default), or 1 for Inches of Mercury
Set Pressure Units	<i>aXPUf!</i>	
Report Rain Units	<i>aXRU!</i>	<i>aXRUF!</i> <CR><LF> Where <i>a</i> = address, and <i>f</i> = 0 for mm (default), or 1 for Inches
Set Rain Units	<i>aXRUF!</i>	
Report Version Number	<i>aXRV!</i>	<i>aXVNxx.x!</i> <CR><LF> Where <i>a</i> = address and <i>xx.x</i> = firmware version

8. Modbus

8.1. Modbus operation:

The AIO 2 can be queried for data using the Modbus RTU protocol. The AIO 2 will automatically detect a Modbus data request via its standard RS-232 or RS-485 interface, and will change to Modbus mode, ready to send out data as requested by a connected Modbus Master.

If the AIO 2 is to be used as a Modbus device, it is recommended to set the Output Interval (OI) command to 0 (zero) to turn off the 1/second output, as shown in section 7.1.12. This will prevent any serial traffic conflicts.

The AIO 2 can be assigned a Modbus address between 1 to 247, which allows it to be addressed on a multiple device network. Setting the Modbus address to 0 will disable the Modbus functionality of the AIO 2.

The AIO 2's current measurement data can be polled via Modbus using the 3X and 4X register addresses:

3X Registers

ModBus Name		Addr	Type	Points	
MB_123456	=	0	float	2	Known value for easier Byte Order configuration
MB_SN	=	2	Char	5	Serial Number String
MB_Revision	=	7	char	20	39 Char + Zero Terminator word aligned to 40 bytes
MB_WS	=	100	float	2	Wind Speed
MB_WD	=	102	float	2	Wind Direction
MB_AT	=	104	float	2	Ambient Temperature
MB_RH	=	106	float	2	Relative Humidity
MB_BP	=	108	float	2	Barometric Pressure
MB_Rain	=	110	float	2	Rain (Reset on Read)
MB_Solar	=	112	float	2	Solar Radiation Disregard if not installed
MB_Batt	=	114	float	2	Supply Voltage
MB_Comp	=	116	float	2	Compass Heading

4X Registers

ModBus Name		Addr	Type	Points	
MB_Byte_Order	=	0	Int	1	1 thru 4

9. Appendix B

9.1. Theory of Operation

Wind

The Met One sonic anemometer operates on the principal that the speed of the wind affects the time it takes for sound to travel from one point to a second point. If the sound is traveling in the direction of the wind then the transit time is decreased. If the sound is traveling in a direction opposite the wind then the transit time is increased.

Ambient Temperature

The temperature sensor in the AIO 2 uses a precision Thermistor. This provides highly accurate and stable temperature readings.

Relative Humidity

The relative humidity sensor is a capacitive polymer sensor which is constructed to provide excellent resistance to wetting, dust, dirt, oils, and common environmental chemicals.

Barometric Pressure

The barometric pressure sensor is a stable transducer using nano-technology, yielding a linear and repeatable sensor with low hysteresis.

This piezo-resistive pressure sensor module is mounted on an electronic circuit board within the sensor. A microcontroller controls the operation of the sensor and the data interface.

The microcontroller polls the pressure sensor module once per second for the barometric pressure and the ambient temperature. The raw readings are temperature corrected by the microcontroller.

Fluxgate Compass

The internal compass module is low power and compact. It employs a pair of magneto-resistive sensors, which change with varying magnetic field strengths, to sense the Earth's magnetic field.

The AIO 2 microprocessor measures the output of the internal compass and then corrects the wind direction data for the orientation of the sensor. The output of the AIO 2 wind direction is relative to magnetic North. A user programmable value of Magnetic Declination may optionally be entered through terminal mode. This enables wind direction output relative to True rather than Magnetic North.